S15C Analog Converter (Voltage and Current) - IO-Link Data Reference Guide

IO-Link Data Map

This document refers to the following IODD file: Banner_Engineering-S15C-IU-20200715-IODD1.1.xml. The IODD file and support files can be found on www.bannerengineering.com under the download section of the product family page.

Communication Parameters

The following communication parameters are used.

Parameter	Value
IO-Link revision	V1.1
Process Data In length	32 bits
Process Data Out length	N/A
Bit Rate	38400 bps
Minimum cycle time	3.6 ms

Parameter	Value
Port class	A
SIO mode	Yes
Smart Sensor Profile	Yes
Block parameterization	Yes
Data Storage	Yes

IO-Link Process Data In (Device to Master)

Process Data In is transmitted cyclically to the IO-Link master from the IO-Link device.

Two analog files are supported by the IODD file. The voltage model is presented in mV and the current mode is presented in µA.

If the model is the voltage version, then Process Data Input = value × 0.001 V.

If the model is the current version, then Process Data Input = value × 0.000001 A.

Process Data Input Configuration - Analog Data

Subindex	Name	Number of Bits	Data Values
1	Measurement Value	32	The measurement device value

Example Process Data Input Configuration - Analog Data (Voltage Model)

Octet 0								
Subindex	1	1	1	1	1	1	1	1
Bit offset	31	30	29	28	27	26	25	24
Value	0	0	0	0	0	0	0	0

Octet 1								
Subindex	1	1	1	1	1	1	1	1
Bit offset	23	22	21	20	19	18	17	16
Value	0	0	0	0	0	0	0	0

Octet 2								
Subindex	1	1	1	1	1	1	1	1
Bit offset	15	14	13	12	11	10	9	8
Value	0	0	0	0	0	0	0	1

Octet 3								
Subindex	1	1	1	1	1	1	1	1
Bit offset	7	6	5	4	3	2	1	0
Value	1	1	1	1	1	1	0	1

Original Document
217418 Rev. A

21 April 2021

217418

ПРОМЭЛЕКТРОНИКА/ sales@prom-elec.com

Example Based Upon the Value Above

Measurement Value = 509

Scaled Measurement Value = 0.509 V

Process Data Input Configuration - Digital Measuring Sensor

Subindex	Name	Number of Bits	Data Values
1	Measurement Value	16	The measurement device value
2	Measurement Scale	8	The measurement device scale Voltage = -3 Current = -6

Example Process Data Input Configuration - Digital Measuring Sensor (Voltage Model)

Octet 0								
Subindex	1	1	1	1	1	1	1	1
Bit offset	31	30	29	28	27	26	25	24
Value	0	0	0	0	0	0	0	1

Octet 1								
Subindex	1	1	1	1	1	1	1	1
Bit offset	23	22	21	20	19	18	17	16
Value	1	1	1	1	1	1	0	1

Octet 2								
Subindex	2	2	2	2	2	2	2	2
Bit offset	15	14	13	12	11	10	9	8
Value	0	0	0	0	0	0	1	1

Octet 3								
Subindex	///	///	///	///	///	///	///	///
Bit offset	7	6	5	4	3	2	1	0
Value								

Example Based Upon the Value Above

Measurement Value = 509

Measurement Scale = -3

Scaled Measurement Value = 0.509 V

Parameters Set Using IO-Link

These parameters can be read from and/or written to an S15C-I-KQ or S15C-U-KQ converter. Also included is information about whether the variable in question is saved during Data Storage and whether the variable came from the IO-Link Smart Sensor Profile.

Unlike Process Data In, which is transmitted from the IO-Link device to the IO-Link master cyclically, these parameters are read or written acyclically as needed.

Index	Sub-index	Name	Length	Value Range	Default	Access Rights	Data Storage?	Smart Sensor Profile
0	1-16	Direct Parameter Page 1 (incl. Vendor ID & Device ID)			ro			
1	1-16	Direct Parameters Page 2				rw		
2		Standard Command		130 = Restore Factory Settings 162 = Start discovery 163 = Stop discovery		wo		y
3		Data Storage Index (device-specific list of parameters to be stored)				rw		

Index	Sub-index	Name	Length	Value Range	Default	Access Rights	Data Storage?	Smart Sensor Profile
4-11		*reserved by IO-Link Specification*						
12		**Device Access Locks**						
12	1	Parameter Write Access Lock		0 = off, 1 = on	0	rw	y	
12	2	Data Storage Lock		0 = off, 1 = on	0	rw	y	
12	3	Local Parameterization Lock		0 = off, 1 = on	0	rw	y	
12	4	Local User Interface Lock		0 = off, 1 = on	0	rw	y	
13		Profile Characteristic				ro		
14		PDInput Descriptor				ro		
15		PDOutput Descriptor				ro		
16		Vendor Name string		Banner Engineering Corporation		ro		
17		Vendor Text string		More Sensors. More Solutions.		ro		
18		Product Name string				ro		
19		Product ID string				ro		
20		Product Text string				ro		y
21		Serial Number				ro		
22		Hardware Versopm				ro		
23		Firmware Version				ro		y
24		App Specific Tag (user defined)				rw	y	y
25		Function Tag				rw	y	y
26		Location Tag				rw	y	y
27-35		*reserved*						
36		Device Status	8-bit integer	0 = Device is OK 1 = Maintenance required 2 = Out of specification 3 = Functional check 4 = Failure 5..255 Reserved		ro		
37		Detailed Device Status	Array[6] of 3-octet			ro		
38-39		*reserved*						
40		Process Data Input		*see Process Data In*		ro		
41-57		*unused/reserved*						
60		**BDC1 Setpoints**						
60	1	Setpoint SP1	32-bit Integer		0.004 A 0.2 V	rw		
60	2	Setpoint SP2	32-bit Integer		0.02 A 10 V	rw		
61		**BDC1 Configuration**						
61	1	*reserved*	8-bit Uinteger					
61	2	*reserved*						
61	3	Hysteresis	16-bit Uinteger		0.0001 A 0.05 V	rw		
69		**All-Time Run Time**						
69	1	Run counter	32-bit Uinteger	0..2147483647		ro	y	
70		**Resettable Run Time**						
70	1	Run counter	32-bit Uinteger	0..2147483647	0	rw		
76		**Vendor Specific Configuration**						
76	1	Process Data Input Configuration	8-bit Uinteger	0 = Analog Value 1 = Digital Measurement Value	0	rw		
76	2	IOL Filter Time	16-bit Uinteger		200	rw		

Index	Sub-index	Name	Length	Value Range	Default	Access Rights	Data Storage?	Smart Sensor Profile
78		**All-Time Run Time Event Time**						
78	1	Event Time	32-bit Uinteger	0..2147483647	0	rw	y	
79		**Resettable Run Time Event Time**						
79	1	Event Time	32-bit Uinteger	0..2147483647	0	rw	y	
86		Model Type	8-bit Uinteger	0 = Voltage, 1 = Current	0	ro		
16512		**MDC Descriptor**		**Measuring Data Channel Descriptor - Smart Sensor Profile 2nd Edition**				y
16512	1	Lower Limit	32-bit integer			ro		y
16512	2	Upper Limit	32-bit integer			ro		y
16512	3	Unit	16-bit uinteger	1209 = A, 1240 = V		ro		y
16512	4	Scale	8-bit integer	-6 (µA), -3(mV)		ro		y

IO-Link Events

Events are acyclic transmissions from the IO-Link device to the IO-Link master. Events can be error messages and/or warning or maintenance data.

Code	Type	Name	Description
25376 (0x6320)	Error	Parameter error	Check data sheet and values
36000 (0x8CA0)	Warning	All-time Run Time Event	Event indicating the corresponding configured running time has elapsed.
36001 (0x8CA1)	Warning	Resettable Run Time Event	Event indicating the corresponding configured running time has elapsed.

more sensors, more solutions

© Banner Engineering Corp. All rights reserved