



Product Service

CERTIFICATE

No. Z10 068636 0034 Rev. 00

Holder of Certificate: **Leuze electronic GmbH + Co.KG**In der Braike 1
73277 Owen/Teck
GERMANY**Certification Mark:****Product:** **Safety components**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: PM86013T**Valid until:** 2023-04-19**Date,** 2018-07-23

(Christian Dirmeier)



Product Service

CERTIFICATE

No. Z10 068636 0034 Rev. 00

Parameters:

Degree of protection: IP67, IP69K
Ambient temperature: -20°C...+50°C
Storing temperature: -40°C...+75°C

Tested according to:

2006/42/EC
EN 60947-1:2007/A2:2014
EN 60947-5-2:2007/A1:2012
EN 60947-5-3:2013
EN 61508-1:2010 (SIL 3)
EN 61508-2:2010 (SIL 3)
EN 61508-3:2010 (SIL 3)
EN 61508-4:2010 (SIL 3)
EN 62061:2005/A2:2015 (SILCL 3)
EN ISO 13849-1:2015 (Cat 4, PL e)
EN ISO 14119:2013

Factory(ies):

075157

Models: L300- fff-icd-gggggg-bbbbb-aaaa-eee-hhhhhh

With

fff Cover

blank Standard cover
B1-B99 Raised cover with or without buttons, LEDs, mushroom-switches (protection degree IP65)

i Housing material

M Metal housing

c Inputs, outputs and programming

- 2 Two safety outputs OS1 OS2, Inserted actuator signalling output O3, Locked actuator signalling output O4, Electro-magnet activation input I4 or IE1 and IE2
- 3 Two safety inputs IS1 IS2, two safety outputs OS1 OS2, Inserted actuator signalling output O3, Locked actuator signalling output O4, Electro-magnet activation input I4 or IE1 and IE2
- 4 Two safety inputs IS1 IS2, two safety outputs OS1 OS2, Inserted actuator signalling output O3, Locked actuator signalling output O4, Electro-magnet activation input I4 or IE1 and IE2, Actuator programming input I3
- 5 Two safety inputs IS1 IS2, two safety outputs OS1 OS2, Inserted actuator signalling output O3, Locked actuator signalling output O4, Electro-magnet activation input I4 or IE1 and IE2, Actuator programming input I3, EDM feedback input I5
- 6 Two safety inputs IS1 IS2, two safety outputs OS1 OS2, Inserted actuator signalling output O3, device fault signalling output O4, Electro-magnet activation input I4 or IE1 and IE2, Actuator programming input I3
- 7 Two safety inputs IS1 IS2, two safety outputs OS1 OS2, Inserted actuator signalling output O3 (active low), device fault signalling output O4 (active low), Electro-magnet activation input I4 or IE1 and IE2, Actuator programming input I3



Product Service

CERTIFICATE

No. Z10 068636 0034 Rev. 00

d Safety outputs activation mode

- 1 Mode 1: Activation of OS1 and OS2 with actuator inserted and locked (guard locked)
- 2 Mode 2: Activation of OS1 and OS2 with actuator inserted (guard closed)
- 3 Mode 3: Activation of OS1 output with actuator inserted and locked (guard is closed and locked) and IS1 is active. Activation of OS2 output with actuator inserted (guard is closed only) and IS2 active. Mode 3 only: SIL 2, Cat. 2 / PL d

gggggg Preinstalled connectors (Non Safety)

An additional alphanumeric code could be added to product code for customer's
e.g.: M12B8: M12 connector on bottom, 8-pins

bbbbbb Functioning mode

- | | |
|-------|---------------------------------|
| SLM24 | Power to unlock (Spring Locked) |
| MLM24 | Power to lock (Magnet Locked) |

aaaa Actuator head

- | | |
|-------|---|
| Blank | Standard head |
| KY | key operated auxiliary switch head |
| KYPB | key operated auxiliary switch and anti-panic release push button head |
| PB | anti-panic release push button head |

eee Actuator

- | | |
|-------|---|
| Blank | provided without actuator |
| SCA | provided with AC-L300-SCA, actuator with low coding level
(standard code actuator) |
| UCA | provided with AC-L300-UCA, actuator with high coding level
(unique code actuator) |

hhhhhh additional alphanumeric code (Non Safety)

An additional alphanumeric code could be added to product code for customer's non-electrical variations (e.g. color, gold plated contacts, special labelling, special packaging, release button length).

Zertifizierungsvertrag

Grundlage für die Zertifikatserteilung ist die Prüf- und Zertifizierungsordnung von TÜV SÜD Product Service.

Mit Erhalt des Zertifikates erkennt der Zertifikatsinhaber die jeweils gültige Fassung der Prüf- und Zertifizierungsordnung an (www.tuev-sued.de/ps_regulations) und wird somit Partner im Zertifiziersystem von TÜV SÜD Product Service.

Prinzipielle Voraussetzung für die Gültigkeit des Zertifikates:

- Gültigkeit der zitierten normativen Prüfgrundlage(n) ist gegeben und zusätzlich bei Zertifikaten mit Berechtigung zur Verwendung eines Prüfzeichens bzw. bei Zertifikaten für QM-Systeme:
- Voraussetzungen für vorschriftsmäßige Fertigung werden eingehalten.
- Die Fertigungs- bzw. Betriebsstätten werden regelmäßig überwacht.

Certification contract

Certification is based on the TÜV SÜD Product Service Testing and Certification Regulations. On receipt of the certificate the certificate holder agrees to the current version of the Testing and Certification Regulations (www.tuv-sud.com/ps_regulations) and thus becomes partner in the TÜV SÜD Product Service Certification System.

Requirements for the validity of the certificate in principle:

- Validity of the quoted test standard(s) In addition, for certificates with the right to use a certification mark and for QM certificates:
- Conditions for an adequate manufacturing are maintained
- Regular surveillance of the facility is performed

认证合约

认证基于 TÜV SÜD 产品服务《测试及认证准则》。获得证书即表明证书持有者接受当前版本的《测试及认证准则》（见 www.tuv-sud.com/ps_regulations）并成为 TÜV SÜD 产品服务认证系统内的合作伙伴。

维持证书有效性的原则要求：

- 认证所依据标准的有效性
- 此外，对于授权可使用认证标志的证书和质量管理体系证书：
- 保持充分的生产条件
 - 生产场地通过定期的监督

認證契約

認証は TÜV SÜD Product Service の試験認証規約に基づく。認証書保持者は認証書を受領することにより最新の試験認証規約(www.tuv-sud.com/ps_regulations)に同意したものとする。その結果、TÜV SÜD Product Service 認証システムのパートナーとなる。

認證書の有効性に関する原則的な要求事項

- 引用している試験規格が有効である
- さらに認証マークの使用を許諾された認証書や品質マネジメント認証書は：
- 適切な製造の条件を維持している
 - 定期的な工場監査を実施している

Contrato de certificação

A certificação se baseia nos Regulamentos de Testes e Certificação do Grupo TÜV SÜD. Ao receber o certificado, o Fornecedor, titular do certificado concorda com a versão atual dos Regulamentos de Testes e Certificação do Grupo TÜV SÜD (www.tuv-sud.com/ps_regulations) e assim, torna-se parceiro no Sistema de Certificação de Produtos e Serviços TÜV SÜD.

Requisitos para a validade do certificado (em princípio):

- Validade da(s) norma(s) de ensaio(s) referenciada(s).
- Adicionalmente, para os certificados com o direito ao uso da marca de certificação e para certificados de SG:
- Condições de fabricação adequada estão mantidas.
 - Auditoria de monitoração realizada regularmente.