



Product Service

CERTIFICATE

No. Z10 17 01 68636 024

Holder of Certificate: Leuze electronic GmbH + Co.KG

 In der Braike 1
 73277 Owen/Teck
 GERMANY

Factory(ies): 68636

Certification Mark:

Product: Electro-Sensitive Protective Equipment
 Safety Light Beam Device

Model(s): MSI-TRM with Sensorhead SLS-Series

Parameters:

Response Time:	2.5ms for the SLS46C 1.0ms for the SLS518 130.0ms for MST-TRM
Power Supply:	24 V DC $\pm 15\%$ (SELV)
Degree of Protection:	IP67, IP 69K for the SLS46C IP67 for the SLS518 IP20 for the MSI-TRM

Tested according to:

EN 61496-1:2013 (Type 4)
EN 61496-2:2013 (Type 4)
ISO 13849-1:2015 (Cat.4, PL e)
EN 62061:2005/A2:2015 (SILCL 3)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: LO88486C

Valid until: 2022-01-24

Date, 2017-02-10

Page 1 of 1

 (Jürgen Blum)
