CERTIFICATE

Number:	UKCA/0558/21/308	**Replaces:**	18GR0580/00
Issue Date:	06-12-2021	**Contract Number:**	PS7133
Due Date:	06-12-2031	**Module:**	B (Type Testing)
Report Number:	124310	**Scope:**	Gas Appliances
PIN:	0063BT1310	**Page**	1 of 2

UKCA TYPE EXAMINATION CERTIFICATE

Kiwa Ltd. hereby declares that the model type(s)

IFD 2xx

Manufactured by Elster GmbH (Honeywell)
Lotte - Büren, Germany

Meet(s) the essential requirements as described in the:

Gas Appliances Regulation (Regulation (EU) 2016/426 as brought into GB law and amended), and the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations 2018 No 389, and amendments to UK SI 2019/696 Product Safety and Metrology, and subsequent amendments, The Product Safety, Metrology and Mutual Recognition Agreement (Amendment) (EU Exit) Regulations 2019 No 1246, and subsequent amendments. This certificate is not valid in Northern Ireland – and is applicable to England, Scotland and Wales only.

Reference standards: BS EN 298:2012, BS EN 14459:2007

Signed on behalf of Kiwa Ltd.
(UK Approved Body Number 0558)

Mark Crowther
Technical Director
Kiwa Ltd.

390/170301

Kiwa Gastec
Kiwa House
Malvern View Business Park
Stella Way
Bishops Cleeve
Cheltenham
GL52 7DQ
United Kingdom
T +44 (0)1242 677877
F +44 (0)1242 676506
www.kiwa.co.uk

UKCA

UKAS PRODUCT CERTIFICATION
0217

ПРОМЭЛЕКТРОНИКА/ sales@prom-elec.com

Number:	UKCA/0558/21/308	**Replaces:**	18GR0580/00
Issue Date:	06-12-2021	**Contract Number:**	PS7133
Due Date:	06-12-2031	**Module:**	B (Type Testing)
Report Number:	124310	**Scope:**	Gas Appliances
PIN:	0063BT1310	**Page**	2 of 2

APPENDIX TO UKCA TYPE EXAMINATION CERTIFICATE

Manufacturer: Elster GmbH (Honeywell)

Types:

IFD 244-x /1 Q (I)
IFD 244-x /2 Q (I)
IFD 244-x /1 W (I) (Z)
IFD 244-x /2 W (I)

IFD 258-x /1 Q (I)
IFD 258-x /2 Q (I)
IFD 258-x /1 W (I)
IFD 258-x /2 W (I)

IFD 258-x /1 Y (I)
IFD 258-x /2 P (I)

x= 3, 5 or 10 s.
Optional (I) integrated Ignition.
Optional (Z) customized version.

Scope:

Application:	Appliances burning gaseous and permanent operation (Ionisation) Appliances burning gaseous and non-permanent operation (UV detector)
Flame detection:	Ionisation, external UV detector UVS
Applied technology:	Complex electronics
Ambient temperature:	-20 °C to +60 °C
Electrical supply:	(P)100 - (R)115 - (Q)120 - (Y)200 - (W)230 Vac 50/60Hz
Protection:	With enclosure and IP 54
Installation environment	Pollution degree 1, 2 or 3
Gas valve output:	Urated.max. 1.0 A

See the installation and operating instructions for all specifications and possible options available for the above listed type(s).

Approved safety relevant functions:

Automatic burner control system:	EN 298	Class C
Reset function:	EN 14459, Annex J	Class B

Remarks/special conditions:
None.

Kiwa Gastec, Kiwa House, Malvern View Business Park, Stella Way, Bishops Cleeve, Cheltenham, GL52 7DQ, United Kingdom