



AGA CERTIFIED PRODUCT



Certificate Holder: **ELSTER GMBH**

ABN/ACN No. (if applicable): N/A

Agent (if applicable): N/A

Type of Component: **Independent Flame Detector Device**

Model No. & Description: **Kromschroder UVC1**
(Refer www.aga.asn.au for more details)

Ambient Temperature Range -20° to 80°C
Suitable for permanent operation

Relevant Standard(s): **EN 298 – 2022**
Automatic gas burner control systems for gas burners and gas burning appliances with or without fans

AS 4625 – 2008
Electronic Flame Safeguards and Flame Detectors

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Client Manager

Certificate Authorised

Certificate first issued: **22 June 2017**

Certificate No: **8586**

This copy valid from: **21 November 2025**

Refer specification issue: **03**