



Number	18GR0024/01	Replaces	18GR0024/00
Issue date	19-09-2025	Contract number	E 0001
Due date	19-09-2035	Module	B (Type testing)
Report number	180100583	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DN0583		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the **safety device**, model(s):

UVC1

Manufacturer

**Elster GmbH (Honeywell)
Strotheweg 1
49504 Lotte - Büren
Germany**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 298:2022

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Wilmsdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands

<https://www.kiwaenergy.com>





Number	18GR0024/01	Replaces	18GR0024/00
Issue date	19-09-2025	Contract number	E 0001
Due date	19-09-2035	Module	B (Type testing)
Report number	180100583	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DN0583	Page	1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:
Elster GmbH (Honeywell)

Model(s):
UVC1

Specifications:

Applied technology:	Complex electronics
Electrical supply:	100..230 Vac (-15% +10%) 50/60 Hz
Ambient temperature:	-20 °C to +80 °C
IP protection degree:	IP 65
Flame detection:	UV

Approved safety relevant functions:

Flame detector device:	EN 298	Class C
------------------------	--------	---------

See the installation and operating instructions for all specifications and possible options available for the above listed type(s).

Remarks/special conditions:
None.